REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

Certificate

No. 122 DATE 29/07/2026

It is certified that an inspection team headed by– ***Mr. Jai Kishan Kumar (Assistant Chemist)*** *from* ***P. H. Division Bhagalpur East. Bhagalpur*** *inspected the* ***Sant Pathik Vidyalaya Ratanganj, Bhagalpur*** *on* ***25.07.2026*** *and found the* ***Sant Pathik Vidyalaya Ratanganj, Bhagalpur*** *has safe drinking water facilities for the students and members of staff institution and is maintain the hygienic sanitation condition in the school campus as per the norms prescribed by the Central/State/ U.T Govt.*

The above valid for a period of- ***One Year (29.07.2026 to 28.07.2027)***.

Kumar

Signature With Seal:- 29/07/26

Name :- Sanjay Kumar Paswan

Designation :- Assistant Research Officer

REGIONAL WATER TESTING LABORATORY * BHAGALPUR *

To,
Sant Pathik Vidyalaya
Ratanganj,
Bhagalpur
Bihar
812006

Government Of Bihar

Regional Water Testing Laboratory

Public Health Engineering Department,

Bhagalpur

Name of Agency :-Sant Pathik Vidyalaya

Sample Collected By- Lab Staff

Source of Sample- R.O water

Ref.No. EE-2709 Dt-22/07/2026

Date of Sampling - 25.07.2026

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location					Physico - Chemical and Bacteriological Parameters														Remarks
	Block	Panchayet	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO_3	SO_4	F	As	Microbial	
1	Sant Pathik Vidyalaya Ratanganj , Bhagalpur - 812006					7.10	0.85	123.6	62.3	31.7	12.7	5.5	15.5	27.4	0.15	2.46	5.4	0.08	NA	Negative	
	Desirable Limit*					6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-	
	Permissible Limit* in absence of alternate source					NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**	

NA=Not Applicable

Date 29/07/2026

Memo No...RL-122

Copy Forwarded To :1. Executive Engineer, P.H.Division Bhagalpur East, for kind information and necessary action.

Kumar
29/07/26
Lab Incharge(A.R.O)